



TECHNICAL SHEET

PANEL APA R20/22



RADIANT PANEL



PREFABRICATED WATER RADIANT PANEL FROM FIREPROOF GYPSUM-BOARD FOR RADIANT HEATING/COOLING
THROUGH THE CEILING AND THROUGH THE WALL

PANEL APA R20/22


The prefabricated radiant panel made of a 15 mm thick fireproof plasterboard board, which contains a spiral type circuit with a PE-XC $\text{\O} 8*1$ pipe (with an oxygen barrier positioned at 50 mm distance from each other) and a 27 mm thick polystyrene board with a density of 26 kg/m^3 . The surface of the radiant panel has good mechanical resistance, moisture resistance and fire resistance.






FIELD OF APPLICATION	
RESIDENTIAL AND NON-RESIDENTIAL	TYPE OF ASSEMBLY
New houses and under renovation	Ceiling
Wooden houses	Wall
Passive houses	
Houses on metal structure	
New apartments and under renovation	
Offices	
Schools	
Hospitals	



<u>PANEL APA R20/22 radiant panel</u>	
<u>EXTERNAL DIMENSIONS</u>	<u>2600X1200X42</u>
<u>TOTAL THICKNESS</u>	<u>42 mm</u>
<u>PLASTER-BOARD THICKNESS</u>	<u>15 mm</u>
<u>POLYSTYRENE BOARD THICKNESS</u>	<u>27 mm ESP200</u>
<u>THERMAL CONDUCTIVITY OF PLASTER-BOARD</u>	<u>W/MK 0,3</u>
<u>INSULATION THERMAL CONDUCTIVITY</u>	<u>W/MK 0.33</u>
<u>FIRE REACTION CLASS</u>	<u>A1</u>
<u>PIPE DIAMETER</u>	<u>8*1 mm</u>
<u>PIPE MATERIAL</u>	<u>PE-XC with oxygen barrier</u>
<u>ASSEMBLY DISTANCE</u>	<u>50mm</u>
<u>CIRCUIT TYPE</u>	<u>Serpentine</u>
<u>TOLERANCE</u>	<u>± 0,5</u>
<u>OPERATING TEMPERATURE</u>	<u>Heating 25-32 °C Cooling 14-20 °C</u>

Length (mm)	Width (mm)	Thickness (mm)	Weight (kg)	Circuit length (mt)	Water content (ml)	Surface (mP)
1200	2600	42	41	60	1,90	3.12
1200	2080	42	32.80	48	1,52	2.49
1200	1650	42	24.60	36	1,14	1.87
1200	1040	42	16.4	24	0,76	1.24
1200	520	42	8.20	12	0,38	0.62









TEST REPORT for determining the heating capacity of warm surfaces for rooms in
accordance with EN 14240



21.58.CIO.002/A1

Page 5 / 14

7. Test results

The values presented in this test report are rounding values based on exact measured values. Hence, in case of any recalculation using these values, the results can differ from the data given in this test report.

All test results relate only to the items tested.

Graphic characteristics are located on pages 6 and 7, the measurement protocol is shown on page 8.

Characteristic equation of thermal output related to active area:

$$\Phi_L = k \cdot \Delta T^n \text{ [W/m}^2\text{]}$$


Coefficient $k = 3,591$

Exponent $n = 1,067$

Standard thermal output related to active area at $\Delta T = 15 \text{ K}$:


$$\Phi_L = 64,6 \text{ W/m}^2$$

Stuttgart, 08.02.2022



.....
Dipl.-Ing. (BA) Thomas Haase
(Technical Manager of the Laboratory)


.....
M. Sc. Andrea Heindl
(Test Manager)

Characteristic equation of thermal output:



Characteristic equation of specific thermal output, related to active area:



8. Measurement protocol

Results of test					
	Symbol	Unit	Measuring point		
			1	2	3
Date of measurement			24.11.2021	24.11.2021	25.11.2021
Air pressure	p	kPa	98,60	98,31	97,83
Reference room temperature	t_{ref}	°C	20,01	20,01	19,99
Inlet water temperature	t_1	°C	42,48	31,81	53,52
Outlet water temperature	t_2	°C	38,55	29,83	47,52
Water temperature drop	$t_1 - t_2$	K	3,93	1,98	6,00
Inlet water enthalpy	h_1	kJ/kg	177,85	133,26	224,01
Outlet water enthalpy	h_2	kJ/kg	161,42	124,97	198,93
Enthalpy difference	$h_1 - h_2$	kJ/kg	16,43	8,29	25,08
Mean water temperature	t_m	°C	40,51	30,82	50,52
Temperature difference	ΔT	K	20,51	10,81	30,53
Water flow rate	q_m	kg/h	258,1	258,1	258,2
Measured thermal output	Φ_{me}	W	1178,0	594,5	1798,8
Output corrected for barometric pressure*	Φ	W	1182,5	597,0	1807,7
Thermal output related to active surface	Φ_L	W/m ²	90,2	45,6	138,0
Control temperatures					
	Unit	Measuring point			
		1	2	3	
Air temperature 0,25 m above floor	°C	19,1	19,5	18,6	
Air temperature 0,75 m above floor	°C	19,3	19,6	19,0	
Air temperature 1,7 m above floor	°C	20,2	20,1	20,2	
Air temperature in the void	°C	32,2	26,5	38,3	
Surface temperature wall 1	°C	18,3	19,1	17,6	
Surface temperature wall 2	°C	18,3	19,1	17,6	
Surface temperature wall 3	°C	18,4	19,1	17,7	
Surface temperature wall 4	°C	18,3	19,1	17,6	
Surface temperature wall 5 (floor)	°C	18,5	19,1	17,8	
Surface temperature wall 6 (ceiling)	°C	18,2	19,0	17,5	

$$* \Phi = \Phi_{me} \cdot (0,65 + 0,35 \cdot (101,325/p)^{0,4})$$



21.58.CIO.001

Page 5 / 14

7. Test results

The values presented in this test report are rounding values based on exact measured values. Hence, in case of any recalculation using these values, the results can differ from the data given in this test report.

All test results relate only to the items tested.

Graphic characteristics are located on pages 6 and 7, the measurement protocol is shown on page 8.

Characteristic equation of cooling capacity related to active area at nominal cooling water flow rate:

$$P_a = k \cdot \Delta\theta^n \text{ [W/m}^2\text{]}$$

Coefficient $k = 5,381$

Exponent $n = 1,029$

Nominal cooling capacity related to active area at $\Delta\theta_N = 8 \text{ K}$ and nominal cooling water flow rate:

$$P_a = 45,7 \text{ W/m}^2$$

Stuttgart, 06.12.2021


Handwritten signature of Thomas Haase in blue ink, positioned above a dotted line.

Dipl.-Ing. (BA) Thomas Haase
(Technical Manager of the Laboratory)


Handwritten signature of Andrea Heindl in blue ink, positioned above a dotted line.

M. Sc. Andrea Heindl
(Test Manager)

Characteristic equation of cooling capacity:



Characteristic equation of specific cooling capacity, related to active area:



8. Measurement protocol

Results of measurements					
Number of measuring point			1	2	3
Date of measurement			23.11.2021	23.11.2021	24.11.2021
Cooling water flow rate [kg/h]		q_w	233,6	233,5	233,4
Temperatures [°C]	Water inlet	θ_{w1}	16,66	18,92	14,45
	Water outlet	θ_{w2}	18,76	20,50	17,04
	Globe	θ_g	26,07	26,10	26,09
	Air - 1,7 m	$\theta_{a1,7}$	26,3	26,3	26,3
	Air - 1,1 m	$\theta_{a1,1}$	26,4	26,3	26,4
	Air - 0,1 m	$\theta_{a0,1}$	26,3	26,3	26,4
	Surface wall 1	θ_{sw1}	26,2	26,2	26,1
	Surface wall 2	θ_{sw2}	26,2	26,2	26,2
	Surface wall 3	θ_{sw3}	26,2	26,2	26,2
	Surface wall 4	θ_{sw4}	26,2	26,2	26,2
	Surface inside floor	θ_{floor}	26,1	26,1	26,1
	Surface inside ceiling	$\theta_{ceiling}$	26,1	26,1	26,1
	Air - void	θ_{a-void}	21,7	22,6	20,8
Heating capacity - dummies [W]		P_s	554,0	411,0	687,0
Calculations from measurements					
Number of measuring point			1	2	3
Reference temperature [°C]		θ_{ref}	26,07	26,10	26,09
$\Delta\theta$ [K]	Water temperature rise	$\Delta\theta_w$	2,10	1,58	2,59
	Reference mean water	$\Delta\theta$	8,35	6,39	10,34
Cooling capacity	Specific - test room area [W/m ²]	P_t	38,7	29,2	47,9
	Specific - installation area [W/m ²]	P_i	40,6	30,6	50,3
	Specific - active area [W/m ²]	P_a	48,0	36,2	59,4
	Total [W]	P	569,2	429,4	704,2
Heat transfer/ test room periphery [W]		P_B	22,2	17,3	25,2
Heat balance [W]		ΔQ	6,9	-1,2	7,9
Heat balance maximum value [W]		$0,05 \cdot P$	+/- 28,5	+/- 21,5	+/- 35,2

TEST REPORT for determining the heating/cooling capacity of hot/cold surfaces in accordance with EN 14240

Heating/cooling through the ceiling
Plasterboard water radiant panel

Plasterboard water radiant panel, PE-XC Ø 8*1 mm pipe, installation distance between pipes: 50 mm.

Test report

No: 21.58.CIO.002/A02 - HEATING

Thermal performance - heating

Temperature in the flow of the radiant panel	W/m ²	
8k (28°C)	33,02	
9K (29°C)	37,44	
10K (30°C)	41,90	
11K (31°C)	46,38	
12K (32°C)	50,89	
13K (33°C)	55,43	
14K (34°C)	59,99	
15K (35°C)	64,50	
16K (36°C)	69,18	
17K (37°C)	73,80	
18K (38°C)	78,44	
19K (39°C)	83,10	
20K (40°C)	87,78	
21K (41°C)	92,47	
22K (42°C)	97,18	
23K (43°C)	101,90	
24K (44°C)	106,63	

Nominal capacity: 64,6 W/m² (Δt : 15K)

(active surface ratio: 100%; active surface: 14,01m²)

Test report

No: 21.58.CIO.001/A01 - COOLING

Thermal performance – cooling


Temperature in return of the radiant panel	W/m ²	
12k (14°C)	69,39	
11K (15°C)	63,45	
10K (16°C)	57,52	
9K (17°C)	51,61	
8K (18°C)	45,72	
7K (19°C)	39,85	
6K (20°C)	34	
5K (21°C)	28,19	
4K (22°C)	22,40	

Nominal capacity: 45,7 W/m² (Δt : 8K)

(active surface ratio: 100%; active surface: 14,01m²)

Panelradiant S.R.L.

ORADEA (BH)



Panelradiant S.R.L.
Str. Principatele Unite, nr. 18, Oradea, Romania
tel: +39 3291660693
+40 744956730
e-mail: panouriradianteapa@gmail.com
web: www.panelradiant.ro

